



Specifications for the Hydro Model 3X6C Gas Chlorination System

HYDRO GAS CHLORINATION SERIES 3X6C for up to 500 PPD CHLORINE FEED

1.01 GENERAL

1.01.1 Completeness

The system shall be complete with all components, equipment, and appurtenances.

1.01.2 Quality Assurance

All materials and components shall be new and unused of first quality by well-known manufacturers. Inferior materials or components shall not be allowed.

1.02 MANUFACTURER

The manufacturer shall be Hydro Instruments, Telford, PA, USA or approved equal. The chlorination system shall be Hydro Instruments Series 300.

1.03 CHLORINATION SYSTEM

1.03.1 General

1. The Chlorination system shall be a vacuum operated, solution feed, automatic, switchover type for dispensing chlorine gas from industry standard one Ton (2000 pound) chlorine cylinders.
2. The Chlorination system shall have a chlorine gas feed capacity of up to 500 pounds per day (2 kg/hr).
3. The system shall convey the gas under vacuum from the ton container mounted vacuum regulators to the ejector assemblies.
4. The chlorination system shall automatically switch the gas supply from an empty container to a full one.
5. The system design shall permit the entire system to be vacuum checked in the field without the use of special tools.
6. The system shall be constructed of materials suitable for wet or dry chlorine gas service. All springs shall be of tantalum alloy.

1.03.2 Cylinder Mounted Vacuum Regulators

1. The two (2) vacuum regulators shall mount directly on the gas cylinder valves, of the Ton cylinders, by means of a corrosion resistant and

gasketed yoke assemblies complying with the standards of The Chlorine Institute, Inc.

2. The inlet adapter shall be constructed of corrosion resistant Hastelloy C material
3. The vacuum regulator body parts shall be constructed of solid machined PVC material for maximum cracking resistance.
4. Each regulator shall have a spring-opposed diaphragm that controls vacuum and closes tight upon loss of vacuum.
5. Each regulator shall incorporate a pressure relief (vent) valve with separate ports for chlorine feed and chlorine vent. Automatic switchover vacuum regulators, which compromise safety by having a single exit port for vent and feed and rely on a detent mechanism and external pressure relief (vent) valve, shall not be acceptable.
6. Connections shall be provided for tubing vented gas away from the pressure relief (vent) port of each vacuum regulator to atmosphere outside the building. The outside end of the vent tubing shall be equipped with an insect screen.
7. The Ton mounting yoke assembly shall include a drip leg with 25-Watt heater to trap and evaporate any liquid chlorine exiting the cylinder valve.
8. Each regulator shall be equipped with an inlet filter to remove particulate matter from the gas before it enters the inlet safety valve.
9. Each regulator shall include a flow meter tube to indicate feed rate and which container is in use.
10. Flow meter tubes shall indicate flow rates up to 500 pounds per day and down to a minimum of 1/20 of the maximum value.
11. Each regulator shall include a mechanism to indicate when the cylinder is empty and requires replacement.

1.03.3 Automatic Switchover Module

1. One (1) separate mechanical device shall be provided to automatically switch from empty container to the standby container. The switchover module shall be suitable for wall mounting.

1.03.4 Gas Flow Meter

1. One (1) gas flow meter shall be provided to indicate the gas flow rate. The gas flow meter shall be suitable for wall mounting.
2. This gas flow meter shall be equipped with a control valve for manual feed rate adjustment.
3. Flow meter tubes shall indicate flow rates up to 500 pounds per day and down to a minimum of 1/20 of the maximum value.

1.03.5 Ejector

1. One (1) ejector shall be water operated venturi nozzle type. The ejector shall provide the operating vacuum for the chlorination system.
2. The ejector shall incorporate a spring loaded, normally closed check valve to prevent the backflow of water into the chlorine gas equipment. The

check valve shall be suitable for back pressures up to a minimum of 100 psi.

3. Ejector check valve shall automatically close upon the loss of vacuum in the Ejector.